

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7150-0328:0156 Page 1 of 1

**CATEGORY:** 7150 -- FIRE ALARM PULL BOXES

**LISTEE:** Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, 63042 United States  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: BillW@pottersignal.com

**DESIGN:** Models P32-1T (allen or key, no push bar) and P32-1T-LP (key lock or allen key) noncoded manual pull stations. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 10 Amp. @ 120 VAC, 30VDC

**INSTALLATION:** In accordance with listee's printed installation, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as manual pull stations for use with separately listed and compatible fire alarm control units.  
These manual pull boxes meet the requirements of UL Standard 38, 1999 Edition with California amendments.

**XLF:** 7150-1039:0101

\*Rev 8-3-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division