


# ASB-6 Detector Sounder Base Wiring



- Notes:**
- Sounder base requires a separate address from the detector
  - 24VDC power for the Sounder base must be coded if a coded output is required