

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	7770-032	7770-0328:0010					
CATEGORY:	7770 - VALVES/SWITCHES						
LISTEE:	Contact:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com					
DESIGN: Supervisory switches listed below to monitor pressure, OS&Y, gat temperature or water level valves. Refer to listee's data sheet for description and operational considerations.							
	Н	ILS-B	WLS-W	WLS-S		PS-40A	
	Р	S-120A	OSYSU-2	OSYS-B	PMS		
	Р	TS-B	OSYSU-1	GVS		PCVS-1	
	2 P	PIVS-B	TTS-S	тт	TTS-W PCVS-		
	V	VLS	PTS-C	PS40	PS40		
	R	RBVS	*PS15	*PS25			
RATING:							
INSTALLATION:		In accordance with listee's printed instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.					
MARKING:	Listee's r	Listee's name, model designation and FM or UL label.					
APPROVAL:	Listed as	Listed as sprinkler system supervisory switches.					
NOTES:	Formerly	Formerly 7738-0328:010					

*Revision 09-07-2016 dc



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/09/2023 Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator Fire Engineering & Investigations Division