

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7165-0328:0170

Page 1 of 1

**CATEGORY:** 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

**LISTEE:** Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, 63042 United States  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: BillW@pottersignal.com

**DESIGN:** Model PFC-4410RC and PFC-4410ARC fire alarm control units. Automatic, manual, noncoded, local, remote station, central station, releasing device, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. Minimum system components:

PFC-4410RC	Control Unit
PFC-4410ARC	Control Unit with LED annunciator

Suitable for use with the following modules: RA-4410RC, CA2Z, CAM, ARM-1, ARM-2, \*ARM-44 and SG-32.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control units when use with separately listed electrically and functionally compatible initiating and indicating devices. Suitable for high-rise applications when used with separately listed voice evacuation systems. Refer to listee's Installation Instruction Manual for details.  
These control units do not generate a Temporal Pattern Signal. If the distinctive three-pulse Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal.  
Model PFC-4410RC control unit meets the requirements of UL Standard 864, 9th edition.  
Model PFC-4410ARC control unit meets the requirements of UL Standard 864, 8th edition.

**NOTE:** Combined with 7170-0328:171

\*Rev 06-18-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*