



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7610-0328:0185
CATEGORY:	7610 - MISC. ACCESSORIES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
DESIGN:	Model QRS and EDPA Accelerator System for Dry Pipe Valves. System consists of a Potter Model QRS Quick Release Pressure Switch, Potter Model PFC-4410-RC Fire Alarm Releasing Panel, Skinner Model 73218BN4UNLVNOC111C2 solenoid valve and trim. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	120 VAC 165VA - 60Hz 220 VAC 185VA - 50-80Hz
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating and FM label.
APPROVAL:	Listed as an accelerator for compatible dry pipe and preaction valves. Refer to manufacturer's Installation Manual for Details.
NOTES:	

06-01-10 fm



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/09/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division