

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7315-0328:0189

Page 1 of 1

CATEGORY: 7315 -- POWER UNITS

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042 United States
Contact: Bill Witherspoon (314) 595-6731 Fax (314) 595-6999
Email: BillW@pottersignal.com

DESIGN: Models PSN-106, PSN-64, PSB-10 Notification Appliance Circuit (NAC) Power Supply Units.
Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Input 120/240 VAC 50/60Hz
Output 24VDC @ 10A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For fire alarm use, the unit must provide battery backup suitable for at least 24 hours.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as power supply units for use with separately listed compatible fire alarm control units and notification appliances. Authority having jurisdiction should be consulted prior to installation. The unit can be programmed to generate the three-pulse temporal fire alarm evacuation signal (for total evacuation) in accordance with NFPA 72, 2002 edition.

01-27-2010 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division