



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING & INVESTIGATIONS DIVISION  
 BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7165-0328:0198
<b>CATEGORY:</b>	7165 - FIRE ALARM CONTROL UNIT (COMMERCIAL)
<b>LISTEE:</b>	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
<b>DESIGN:</b>	<p>Models PFC-6500, PFC-6500R, P400, *P400R and PFC-6800 fire alarm control panels Automatic, Manual, waterflow and sprinkler supervisory type device and local, auxiliary, releasing, remote station (PPU), proprietary (PPU) and central station (PPU) services. Refer to listee's Installation Instruction Manual for details. System components:</p> <p>CA-6500: Class A Expander</p> <p>UD-1000: DACT</p> <p>*3006607,*3006610,*3006623,*3006623,*3006618 : Main Boards</p> <p>RA-6075, RA-6075R, RA-6500: Remote Annunciators</p> <p>3005013, 3005012: EOL Resistors</p> <p>PSN-1000, PSN-1000(E): Fire Power Expander</p> <p>Models AE-8, AE-14; Power expander enclosures</p> <p>SLCE-127: Loop Expander</p>
<b>RATING:</b>	24 VDC
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model designation, rating and UL label.
<b>APPROVAL:</b>	Listed as fire alarm control units when use with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

\*Rev 02-08-16 dc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/09/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Victor Wong**, Program Coordinator  
Fire Engineering & Investigations Division