

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7320-0328:0207

Page 1 of 1

**CATEGORY:** 7320 -- SPEAKERS

**LISTEE:** Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, 63042 United States  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: billw@pottersignal.com

**DESIGN:** Models SPKSTR-24WLP and SPKSTR-24-15/75 speaker strobes. May be followed by suffix -P, -W, or -R (plain, white, or red color). Models CSPKSTR-24A (amber), CSPKSTR-24B (blue), CSPKSTR-24G (green), and CSPKSTR-24R (red). May be followed by A (alert), P (plain) and then followed by W (wall), then followed by R (red) or W (white) All models are intended for indoor use only and are wall mounted in a listed double-gang backbox.

Models SPKSTR-24WLP and SPKSTR-15/75 speaker strobes. May be followed by A (alert), P (plain) then followed by W (wall), then followed by R (red) or W (white). Models CSPKSTR-24A (amber), CSPKSTR-24B (blue), CSPKSTR-24G (green), and CSPKSTR-24R (red), may be followed by A (alert), P (plain) then followed by R (red) or W (white). All models are intended for outdoor use on a wall with the Model GBLP back box.

Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

Speaker	25 Vrms and 70.7 Vrms
Strobe	24 VDC
Flash Rate	60 flashes per minute
Candela	15, 30, 60, 75 & 15/75, 110 for Model SSPK24WLP 15/75 fixed candela for Model SSPK24-15/75WLP

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, ratings, and UL label.

**APPROVAL:** Listed as speakers and speaker strobes for use with separately listed compatible fire alarm control units. Models are suitable for the hearing impaired applications. For indoor or outdoor use. Refer to manufacturer's Installation Manual for details.

**XLF:** 7320-0569:0140

07-24-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*