

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	7300-0328:0215
PARENT LISTING No.:	7300-0569:0124
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
DESIGN:	Model WPBB enclosure. Model WPBB enclosure is for use with listee's separately listed Model EH24 horn (CSFM Listing No. 7135-0328:0217) for indoor or outdoor use, and Gentex Model WGE Series horn/strobe (CSFM Listing No.7135-569:127 and 7135-0569:122) for indoor or outdoor use. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number and UL label.
APPROVAL:	Listed as a back box and enclosure for use with separately listed audible and visual appliances.
NOTES:	

07-24-13 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test resultsand/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 07/03/2023 Listing Expires: 06/30/2024



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

Authorized By: Victor Wong , Program Coordinator Fire Engineering & Investigations Division		