

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 6911-0328:0221 Page 1 of 1

**CATEGORY:** 6911 -- VOICE COMMUNICATION SYSTEMS CONTROL UNITS

**LISTEE:** Potter Electric Signal Co1609 Park 370 Place, Hazelwood, 63042 United States  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: billw@pottersignal.com

**DESIGN:** Models \*PVC-MP and \*PVC-DP audio adjunct/voice evacuation systems. The \*PVC-MP is the master panel in the system while the \*PVC-DP is the distributed panel. Each system is modular in construction. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

PWR-2A; Power Supply  
MFP Master; Fire Phone Card  
DCC ;Data Communication Control Card  
ASC; Audio System Control Card  
SSC; Switch Scan Card  
MMC; Microphone Master Control Card  
IOI; Input/Output Card  
SLC; Switch and LED Card  
MFH; Master Fire Phone Handset Card  
MBR; Motherboard Card  
AMI; Audio Module Interface Card  
FPI; Motherboard/Relay Card  
PVX's Models PVX-25, -25E, -50, -50E, -100 or -100E; Audio Adjunct Systems

**RATING:** 120 VAC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as voice communication/evacuation/relocation/paging system for use separately listed electrically compatible fire alarm control unit. Suitable for high rise applications when used in conjunction with separately listed electrically compatible high rise fire alarm control units. Refer to listee's Installation Instruction Manual for details.

**XLF:** 6911-1446:0103

Revision10-26-16 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*