

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0328:0500 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, 63042 United States
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: billw@pottersignal.com

DESIGN: Models IPA-60, IPA-100, and IPA-4000 fire alarm control units. Automatic, Manual, waterflow and sprinkler supervisory type device and local, auxiliary, releasing, remote station (PPU), proprietary (PPU) and central station (PPU) services. Refer to listee's Installation Instruction Manual for details. System components (CSFM Listing 7305-0328:0200):

- PAD100-DIM Dual Input Module
- PAD100-LED Addressable LED Module
- PAD 100-OROI One Relay-One Input Module
- PAD 100-RM Relay Module
- PAD 100-SIM Single Input Module
- PAD 100 TRTI Two Relay-Two Input Module
- PAD 100-ZM Zone Module
- PAD 100-IM Isolator Module
- PAD 100- NAC Notification Appliance Circuit Module
- PAD 100-SM Speaker Module
- PAD 100-MIM Micro Input Module
- PAD 100-LEDK LED Key Switch Module
- PAD 100-DRTS Duct Remote Test Switch
- PAD 100-SLCE127 Point SLC Expander
- MC-1000 Multi-Connect
- PAD 100-DUCTR
- AE-2 Enclosure

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, rating and UL label.

APPROVAL: Listed as fire alarm control units when use with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

03-07-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division