



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-0328:0547
PARENT LISTING No.:	7300-0785:0184
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	<p>Models PE-SPKBB-x [a], PE-SPKBB-Cx [a], and PE-SBB-x [a] Back Box.</p> <p>Model PE-SPKBB-x is a wall speaker or horn surface back box.</p> <p>Model PE-SPKBB-Cx is a ceiling speaker or horn surface back box.</p> <p>Model PE-SBB-x single-gang wall horn surface back box.</p> <p>[a] - Where x represents product color.</p> <p>Models may be followed by an alphanumeric character indicating product color.</p> <p>Refer to listee's data sheet for additional detailed product description and operational considerations.</p>
RATING:	N/A
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, and UL label.
APPROVAL:	Listed as back boxes for indoor/dry uses. Models complies with the applicable requirements in UL 464, 10th Edition, UL 1480, 6th Edition, UL 1971, 3rd Edition, and UL 1638, 5th Edition. Refer to listee's Installation Instructions Manual for details.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

NOTES:

02-06-24 MH



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 02/08/2024

Listing Expires: 06/30/2024

Authorized By: **David Castillo** , Program Coordinator
Fire Engineering & Investigations Division