



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7135-1517:0123
<b>CATEGORY:</b>	7135 - AUDIBLE DEVICES
<b>LISTEE:</b>	COMMERCIAL PRODUCTS GROUP (CPG) 1609 Park 370 Place, Hazelwood, MO, 63031 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
<b>DESIGN:</b>	<p>Models ASHP, SPHH, SPHX, ASHH and ASHX audible devices. Suitable for outdoor use. May include the following optional devices: Models PTCK25, PTCK70 connector cards and Model UTC tone card. Refer to listee's data sheet for detailed product description and</p> <p>operational considerations. Additional information may also be located in UL Hazardous Locations Equipment Directory and UL Fire Protection Equipment Directory.</p>
<b>RATING:</b>	
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, product designation, electrical rating and UL label.
<b>APPROVAL:</b>	<p>Listed as audible devices for use with separately listed compatible control units. May be used with separately listed compatible visual signal devices.</p> <p>Model ASHH and SPHH are suitable for use in hazardous locations, Class I, Group A, B, C and D, Division 2; Class II, Group F and G, Division 2; and Class III. Model ASHX and SPHX are suitable for use in hazardous locations, Class I, Group B, C and D; Class II, Group E, F and G; and Class III.</p> <p>If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to listee's Installation Instructions Manual for details.</p>
<b>NOTES:</b>	Formerly: 7135-1517:0101



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

07-26-10 fm



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/10/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Victor Wong**, Program Coordinator  
Fire Engineering & Investigations Division