

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 5278-1653:0219 Page 1 of 1

**CATEGORY:** 5278 -- CARBON MONOXIDE DETECTORS

**LISTEE:** System Sensor, Unincorporated Div of Honeywell Int'l Inc. 3825 Ohio Ave, St. Charles, IL 60174  
Contact: Pete Sennett (630) 762-5362 Fax (203) 484-7309  
Email: pete.sennett@honeywell.com

**DESIGN:** Models CO1224, CO1224T, and CO1224TR Carbon Monoxide detectors. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 10-33 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes, NFPA 720, and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, Model number, electrical rating and UL label.

**APPROVAL:** Listed as Carbon Monoxide detectors for use with separately listed fire alarm control units.

**NOTE:** Carbon Monoxide detectors are not intended/suitable for fire and smoke detection.

12-06-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division